



LOWER TRINITY GROUNDWATER CONSERVATION DISTRICT

602 E. Church St. #150
Livingston, TX 77351
Office: (936) 327-9531
Website: WaterWells.Info
Email: District@WaterWells.Info

Water Well Spacing Guidelines *For Operating Year 2026*

Residential Wells:

Pressure cemented wells:

If pressure cemented, Minimum distance from property line-5 feet

If not, pressure cemented -50ft from property line

Water-tight septic tank-50 feet

Soil absorption field-100 feet

Concentrated source of potential contamination, (Cattle yard, Poultry House)-150 feet

Commercial Wells:

Pressure cemented wells:

Minimum distance from property line-150 feet

Water-tight septic tank-150 feet

Soil absorption field-150 feet

Concentrated source of potential contamination-150 feet

